

KESEHATAN DAERAH MILITER ISKNDAR MUDA  
 RUMAH SAKIT TINGKAT II ISKANDAR MUDA

STANDARD PELAYANAN MINIMAL (SPM) RUMAH SAKIT TK II ISKANDAR MUDA

NO	JENIS PELAYANAN	INDIKATOR	SATUAN	STANDAR	PENCAPAIAN AWAL	TARGET (TAHUN)					PENANGGUNG JAWAB
						2017	2018	2019	2020	2021	
XV	PENGELOLAAN LIMBAH	1 Baku mutu limbah cair	mg/l	a. BOD < 30mg/L	a. BOD < 30mg/L	a. BOD < 30mg/L	a. BOD < 30mg/L	a. BOD < 30mg/L	a. BOD < 30mg/L	a. BOD < 30mg/L	Kepala IPSRS
			mg/l	b. COD < 80 mg/L	b. COD < 80 mg/L	b. COD < 80 mg/L	b. COD < 80 mg/L	b. COD < 80 mg/L	b. COD < 80 mg/L	b. COD < 80 mg/L	
			mg/l	c. TSS < 30 mg/L	c. TSS < 30 mg/L	c. TSS < 30 mg/L	c. TSS < 30 mg/L	c. TSS < 30 mg/L	c. TSS < 30 mg/L	c. TSS < 30 mg/L	
			PH	d. PH 6-9	d. PH 6-9	d. PH 6-9	d. PH 6-9	d. PH 6-9	d. PH 6-9	d. PH 6-9	
		2 Pengelolaan limbah padat infeksius sesuai dengan aturan	%	100%	80%	85%	90%	95%	100%	100%	Kepala IPSRS

Kaurdal Situud  
 Rumkit Tk-II IM  
  
 Irwan Setiawan  
 Kapten Ckm Nrp 21970240170677